



DEPARTMENT OF HEALTH & HUMAN SERVICES

Public Health Service
Food and Drug Administration

Dallas District
3310 Live Oak Street
Dallas, Texas 75204-6191

October 10, 1997

Ref:98-DAL-WL- 2

WARNING LETTER

FEDERAL EXPRESS

Mr. John F. Chlebowski, President and CEO
GATX Terminals Corporation
500 W. Monroe
Chicago, Illinois 60661

Dear Mr. Chlebowski:

During an inspection of the GATX Terminal vessel watering point in Galena Park, Texas, on September 29, 1997, our investigator documented deviations from Title 21, Code of Federal Regulations (CFR), Part 1250. Therefore, the referenced vessel watering point has been classified as "Provisional."

Our investigation revealed significant insanitary conditions, including:

1. The check valve on potable water hydrant No. 1 was improperly installed with the check valve turned sideways.
2. The potable water hydrant on ship dock No. 3 was not identified and the outlet was on the same dock with chemical outlets.
3. A keeper chain was not present on the potable water hydrant on ship dock No.2.

This letter is not intended to be an all-inclusive list of deficiencies at your vessel watering point and it is your responsibility to ensure adherence to each requirement of the regulations. You should assure that all vessel watering points under your control are in compliance with the regulations.


A list of Inspectional Observations (FDA-483) was issued to and discussed with a responsible individual at the firm. A copy of the FDA-483 is enclosed for your reference. Please review the observations noted by the investigator at the Houston location

2- Mr. John F. Chlebowski, President and CEO
October 10, 1997

inspected. You should take prompt action to correct these deviations and ensure that future violations do not recur. Failure to correct these critical violations can result in further action by FDA. Your vessel watering point may be placed on a "Not Approved" status if future similar violations occur.

You should notify this office in writing, within fifteen (15) days of receipt of this letter, stating the specific steps you have taken to correct the aforementioned violations. Your reply should be directed to Gwen Gilbreath, Compliance Officer, at the above letterhead address.

Sincerely,


Joseph R. Baca
Dallas District Director

JRB:GSG

cc. Mr. Robert Sease
Vice-President Operations

Mr. Thomas J. Rigg
Director of Operations
GATX Terminals Corp.
906 Clinton
Galena Park, Texas 77547

3- Mr. John F. Chlebowsky, President and CEO
October 10, 1997

Reviewed by: Elaine R. Crosby, DCB *EL Crosby*

bcc: LF/FF/WLF/RF's
HFR-SW1
~~HFI-35 thru CO~~
HFR-SE400 (ITS Specialist - FDA-483 & EIR)
HFC-210 (CFN1623182)
HFA-224
HFS-627 (Larry Edwards)
HFS-607 (Larry E. Glaze)
HFR-SW150 (DIB)
HFR-SW1580 (Graham/Johnson)
TDH